

217/785-1705

FEDERALLY ENFORCEABLE STATE OPERATING PERMIT -- NSPS and NESHAP SOURCE

PERMITTEE

Allstate Insurance Company  
Attn: Patrick J. Sarb  
3075 Sanders Road  
Northbrook, Illinois 60062

Application No.: 09070039  
Applicant's Designation: CH3  
Subject: Network Data Center  
Date Issued:

I.D. No.: 031207AEG  
Date Received: July 22, 2009

Expiration Date:

Location: 2775-3075 Sanders Road, Northbrook, Cook County, 60062

Permit is hereby granted to the above-designated Permittee to OPERATE emission source(s) and/or air pollution control equipment consisting of:

Four (4) 1,500 kW (2,250 engine HP) diesel-powered emergency generator sets (B Building Generator, D Building Generator, South Plaza Generator 4, and South Plaza Generator 5);  
Three (3) 1,750 kW (2,606 engine HP) diesel-powered emergency generator sets (South Plaza Generator 6, South Plaza Generator 7 and South Plaza Generator 8); and  
Two (2) 2,500 kW (3,673 engine HP) diesel-powered emergency generator sets (DG1 & DG2)

pursuant to the above-referenced application. This Permit is subject to standard conditions attached hereto and the following special condition(s):

1a. This Federally Enforceable State Operating Permit is issued:

- i. To limit the emissions of air pollutants from the source to less than major source thresholds, (i.e., 100 tons/year for Nitrogen Oxides (NO<sub>x</sub>)). As a result, the source is excluded from requirements to obtain a Clean Air Act Permit Program (CAAPP) permit. The maximum emissions of this source, as limited by the conditions of this permit are described in Attachment A.
- ii. To limit the emissions of NO<sub>x</sub> from the construction of new emission units and other modifications at the source, which occurred without first obtaining construction permit(s) prior to November 15, 1992, to less than 100 tons/year. As a result, the source is excluded from the requirements of 35 Ill. Adm. Code Part 203, Major Stationary Sources Construction and Modification.
- iii. To establish federally enforceable production and operating limitations, which restrict the potential to emit for NO<sub>x</sub> to less than 100 tons per year so that the source is not subject to the requirements of 35 Ill. Adm. Code Part 217 Subpart Q (Stationary Reciprocating Internal Combustion Engines And Turbines).

- b. Prior to issuance, a draft of this permit has undergone a public notice and comment period.
  - c. This permit supersedes all operating permit(s) for this location.
- 2a. Diesel-powered Emergency Generator Sets DG1 and DG2 are subject to the New Source Performance Standards (NSPS) for Stationary Compression Ignition Internal Combustion Engines, 40 CFR 60 Subparts A and IIII. The Illinois EPA is administering the NSPS in Illinois on behalf of the United States EPA under a delegation agreement. Pursuant to 40 CFR 60.4200(a), the provisions of 40 CFR 60 Subpart IIII are applicable to manufacturers, owners, and operators of stationary compression ignition (CI) internal combustion engines (ICE) and other persons as specified in 40 CFR 60.4200(a)(1) through (4). For the purposes of 40 CFR 60 Subpart IIII, the date that construction commences is the date the engine is ordered by the owner or operator.
- i. Owners and operators of stationary CI ICE that commence construction after July 11, 2005, where the stationary CI ICE are manufactured after April 1, 2006, and are not fire pump engines,
  - ii. Owners and operators of any stationary CI ICE that are modified or reconstructed after July 11, 2005 and any person that modifies or reconstructs any stationary CI ICE after July 11, 2005.
  - iii. The provisions of 40 CFR 60.4208 are applicable to all owners and operators of stationary CI ICE that commence construction after July 11, 2005
- b. Pursuant to 40 CFR 60.4202(b)(2), stationary CI internal combustion engine manufacturers must certify their 2007 model year and later emergency stationary CI ICE with a maximum engine power greater than 2,237 KW (3,000 HP) and a displacement of less than 10 liters per cylinder that are not fire pump engines to the emission standards specified in 40 CFR 60.4202(b)(1) through (2). For 2011 model year and later, the certification emission standards for new nonroad CI engines for engines of the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113 for all pollutants.
- c. Pursuant to 40 CFR 60.4205(b), owners and operators of 2007 model year and later emergency stationary CI ICE with a displacement of less than 30 liters per cylinder that are not fire pump engines must comply with the emission standards for new nonroad CI engines in 40 CFR 60.4202, for all pollutants, for the same model year and maximum engine power for their 2007 model year and later emergency stationary CI ICE.
- 3a. The diesel-powered emergency generator sets are subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines, 40 CFR 63 Subparts A and ZZZZ. The Illinois EPA is administering the NESHAP in Illinois on behalf of the United States EPA under a delegation agreement. Pursuant to 40 CFR 63.6590(a), an affected source is any existing, new, or

reconstructed stationary RICE located at a major or area source of HAP emissions, excluding stationary RICE being tested at a stationary RICE test cell/stand.

- b. Pursuant to 40 CFR 63.6590(c)(1), a new or reconstructed stationary RICE located at an area source must meet the requirements of 40 CFR Part 63 by meeting the requirements of 40 CFR Part 60 Subpart IIII, for compression ignition engines or 40 CFR Part 60 Subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under 40 CFR Part 63.
- c. Pursuant to 40 CFR 63.6595(a)(1), if you have an existing stationary RICE, excluding existing non-emergency CI stationary RICE, with a site rating of more than 500 brake HP located at a major source of HAP emissions, you must comply with the applicable emission limitations, operating limitations and other requirements no later than June 15, 2007. If you have an existing non-emergency CI stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, an existing stationary CI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary CI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations, operating limitations, and other requirements no later than May 3, 2013. If you have an existing stationary SI RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions, or an existing stationary SI RICE located at an area source of HAP emissions, you must comply with the applicable emission limitations, operating limitations, and other requirements no later than October 19, 2013.
- c. Pursuant to 40 CFR 63.6603(a), if you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to 40 CFR 63 Subpart ZZZZ and the operating limitations in Table 2b to 40 CFR 63 Subpart ZZZZ that apply to you.

Table 2d to Subpart ZZZZ of Part 63—Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions

As stated in 40 CFR 63.6600 and 63.6640, you must comply with the following requirements for existing stationary RICE located at area sources of HAP emissions:

For each . . .	You must meet the following requirement, except during periods of startup . . .	During periods of startup you must . . .
4. Emergency stationary CI RICE and black start stationary CI RICE. <sup>2</sup>	a. Change oil and filter every 500 hours of operation or annually, whichever comes first; <sup>1</sup>	
	b. Inspect air cleaner every 1,000 hours of	

	operation or annually, whichever comes first; and	
	c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.	

- <sup>1</sup> Sources have the option to utilize an oil analysis program as described in 40 CFR 63.6625(i) or (j) in order to extend the specified oil change requirement in Table 2d of 40 CFR 63 Subpart ZZZZ.
- <sup>2</sup> If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required in Table 2d of 40 CFR 63 Subpart ZZZZ, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable.
- 4a. Pursuant to 40 CFR 89.112(a), exhaust emission from nonroad engines to which 40 CFR 89 Subpart B is applicable shall not exceed the applicable exhaust emission standards contained in Table 1, as follows:

Table 1.—Emission Standards (g/kW-hr)

Rated Power (kW)	Tier	Model Year <sup>1</sup>	NO <sub>x</sub>	HC	NMHC + NO <sub>x</sub>	CO	PM
kW>560	Tier 1	2000	9.2	1.3	---	11.4	0.54
	Tier 2	2006	--	--	6.4	3.5	0.20

<sup>1</sup> The model years listed indicates the model years for which the specified tier of standards take effect.

- b. Pursuant to 40 CFR 89.112(e), naturally aspirated nonroad engines to which 40 CFR 89 Subpart B is applicable shall not discharge crankcase emissions into the ambient atmosphere, unless such crankcase emissions are permanently routed into the exhaust and included in all exhaust emission measurements. This provision applies to all Tier 2 engines and later models. This provision does not apply to engines using turbochargers, pumps, blowers, or superchargers for air induction.
- c. Pursuant to 40 CFR 89.113(a), exhaust opacity from compression-ignition nonroad engines for which 40 CFR 89 Subpart B is applicable must not exceed:
- i. 20 percent during the acceleration mode;

- ii. 15 percent during the lugging mode; and
- iii. 50 percent during the peaks in either the acceleration or lugging modes.
- d. Pursuant to 40 CFR 89.113(c)(3), constant-speed engines are exempt from the requirements of 40 CFR 89.113.
- 5a. Pursuant to 35 Ill. Adm. Code 212.123(a), no person shall cause or allow the emission of smoke or other particulate matter, with an opacity greater than 30 percent, into the atmosphere from any emission unit other than those emission units subject to the requirements of 35 Ill. Adm. Code 212.122.
- b. Pursuant to 35 Ill. Adm. Code 212.123(b), the emission of smoke or other particulate matter from any such emission unit may have an opacity greater than 30 percent but not greater than 60 percent for a period or periods aggregating 8 minutes in any 60 minute period provided that such opaque emissions permitted during any 60 minute period shall occur from only one such emission unit located within a 305 m (1000 ft) radius from the center point of any other such emission unit owned or operated by such person, and provided further that such opaque emissions permitted from each such emission unit shall be limited to 3 times in any 24 hour period.
- 6a. Pursuant to 35 Ill. Adm. Code 214.122(b)(2), no person shall cause or allow the emission of sulfur dioxide into the atmosphere in any one hour period from any new fuel combustion source with actual heat input smaller than, or equal to, 73.2 MW (250 mmBtu/hr), burning liquid fuel exclusively to exceed 0.46 kg of sulfur dioxide per MW-hour of actual heat input when distillate fuel oil is burned (0.3 lbs/mmBtu).
- b. Pursuant to 35 Ill. Adm. Code 214.301, except as further provided by 35 Ill. Adm. Code Part 214, no person shall cause or allow the emission of sulfur dioxide into the atmosphere from any process emission source to exceed 2000 ppm.
- c. Pursuant to 35 Ill. Adm. Code 214.304, the emissions from the burning of fuel at process emission sources located in the Chicago or St. Louis (Illinois) major metropolitan areas shall comply with applicable 35 Ill. Adm. Code Part 214 Subparts B through F (i.e., 35 Ill. Adm. Code 214.122(b)).
- 7. Pursuant to 35 Ill. Adm. Code 218.301, no person shall cause or allow the discharge of more than 3.6 kg/hr (8 lbs/hr) of organic material into the atmosphere from any emission unit, except as provided in 35 Ill. Adm. Code 218.302, 218.303, or 218.304 and the following exception: If no odor nuisance exists the limitation of 35 Ill. Adm. Code Part 218 Subpart G (Use of Organic Material) shall only apply to photochemically reactive material.

- 8a. Pursuant to 40 CFR 60.11(b), compliance with opacity standards in 40 CFR Part 60 shall be determined by conducting observations in accordance with Method 9 in Appendix A of 40 CFR Part 60, any alternative method that is approved by the Illinois EPA or USEPA, or as provided in 40 CFR 60.11(e)(5). For purposes of determining initial compliance, the minimum total time of observations shall be 3 hours (30 6-minute averages) for the performance test or other set of observations (meaning those fugitive-type emission sources subject only to an opacity standard).
  - b. Pursuant to 40 CFR 60.11(c), the opacity standards set forth in 40 CFR Part 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.
  - c. Pursuant to 40 CFR 60.11(d), at all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Illinois EPA or USEPA which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.
- 9a. Pursuant to 40 CFR 60.4206, owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in 40 CFR 60.4204 and 60.4205 according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer, over the entire life of the engine.
  - b. Pursuant to 40 CFR 60.4207(a), beginning October 1, 2007, owners and operators of stationary CI ICE subject to 40 CFR 60 Subpart IIII that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(a).
  - c. Pursuant to 40 CFR 60.4207(b), beginning October 1, 2010, owners and operators of stationary CI ICE subject to 40 CFR 60 Subpart IIII with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 80.510(b) for nonroad diesel fuel.
  - d. Pursuant to 40 CFR 60.4211(a), if you are an owner or operator and must comply with the emission standards specified in 40 CFR 60 Subpart IIII, you must operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's written instructions or procedures developed by the owner or operator that are approved by the engine manufacturer. In addition, owners and operators may only change those settings that are permitted by the manufacturer.

You must also meet the requirements of 40 CFR parts 89, 94 and/or 1068, as they apply to you.

- e. Pursuant to 40 CFR 60.4211(c), if you are an owner or operator of a 2007 model year and later stationary CI internal combustion engine and must comply with the emission standards specified in 40 CFR 60.4204(b) or 40 CFR 60.4205(b), or if you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to 40 CFR 60 Subpart IIII and must comply with the emission standards specified in 40 CFR 60.4205(c), you must comply by purchasing an engine certified to the emission standards in 40 CFR 60.4204(b), or 40 CFR 60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's specifications.
- f. Pursuant to 40 CFR 60.4211(e), emergency stationary ICE may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Maintenance checks and readiness testing of such units is limited to 100 hours per year. There is no time limit on the use of emergency stationary ICE in emergency situations. Anyone may petition the Illinois EPA or USEPA for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency ICE beyond 100 hours per year. For owners and operators of emergency engines meeting standards under 40 CFR 60.4205 but not 40 CFR 60.4204, any operation other than emergency operation, and maintenance and testing as permitted in 40 CFR 60.4011, is prohibited.
- 10a. Pursuant to 40 CFR 63.6604(b), beginning January 1, 2015, if you own or operate an existing emergency CI stationary RICE with a site rating of more than 100 brake HP and a displacement of less than 30 liters per cylinder that uses diesel fuel and operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in 40 CFR 63.6640(f)(4)(ii), you must use diesel fuel that meets the requirements in 40 CFR 80.510(b) for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to January 1, 2015, may be used until depleted.
- b. Pursuant to 40 CFR 63.6605(a), you must be in compliance with the emission limitations, operating limitations, and other requirements in 40 CFR 63 Subpart ZZZZ that apply to you at all times.
- c. Pursuant to 40 CFR 63.6605(b), at all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with

safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Illinois EPA or USEPA which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.

- d. Pursuant to 40 CFR 63.6625(e)(3), if you own or operate an existing emergency or black start stationary RICE located at an area source of HAP emissions you must operate and maintain the stationary RICE and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.
- e. Pursuant to 40 CFR 63.6625(f), if you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.
- f. Pursuant to 40 CFR 63.6625(h), if you operate a new, reconstructed, or existing stationary engine, you must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup in Tables 1a, 2a, 2c, and 2d to 40 CFR 63 Subpart ZZZZ apply.
- g. Pursuant to 40 CFR 63.6625(i), if you own or operate a stationary CI engine that is subject to the work, operation or management practices in items 1 or 2 of Table 2c to 40 CFR 63 Subpart ZZZZ or in items 1 or 4 of Table 2d to 40 CFR 63 Subpart ZZZZ, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to 40 CFR 63 Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to 40 CFR 63 Subpart ZZZZ. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the



analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

- h. Pursuant to 40 CFR 63.6640(a), you must demonstrate continuous compliance with each emission limitation, operating limitation, and other requirements in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to 40 CFR 63 Subpart ZZZZ that apply to you according to methods specified in Table 6 to 40 CFR 63 Subpart ZZZZ.

Table 6 to Subpart ZZZZ of Part 63—Continuous Compliance With Emission Limitations, and Other Requirements

As stated in 40 CFR 63.6640, you must continuously comply with the emissions and operating limitations and work or management practices as required by the following:

For each . . .	Complying with the requirement to . . .	You must demonstrate continuous compliance by . . .
9. Existing emergency and black start stationary RICE ≤500 HP located at a major source of HAP, existing non-emergency stationary RICE <100 HP located at a major source of HAP, existing emergency and black start stationary RICE located at an area source of HAP, existing non-emergency stationary CI RICE ≤300 HP located at an area source of HAP, existing non-emergency 2SLB stationary RICE located at an area source of HAP, existing non-emergency stationary SI RICE located at an area source of HAP which combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, existing non-emergency 4SLB and 4SRB stationary RICE ≤500 HP located at an area source of HAP, existing non-emergency 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that operate 24 hours or less per calendar year, and existing non-emergency 4SLB and 4SRB stationary RICE >500 HP located at an area source of HAP that are remote stationary RICE	a. Work or Management practices	i. Operating and maintaining the stationary RICE according to the manufacturer's emission-related operation and maintenance instructions; or ii. Develop and follow your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions.

- i. Pursuant to 40 CFR 63.6640(f), if you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in 40 CFR 63.6640(f)(1) through (4). In order for the engine to be considered an emergency stationary RICE

under 40 CFR 63 Subpart ZZZZ, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in 40 CFR 63.6640(f)(1) through (4), is prohibited. If you do not operate the engine according to the requirements in 40 CFR 63.6640(f)(1) through (4), the engine will not be considered an emergency engine under 40 CFR 63 Subpart ZZZZ and must meet all requirements for non-emergency engines.

- i. There is no time limit on the use of emergency stationary RICE in emergency situations.
- ii. You may operate your emergency stationary RICE for any combination of the purposes specified in 40 CFR 63.6640(f)(2)(i) through (iii) for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by 40 CFR 63.6640(f)(3) and (4) counts as part of the 100 hours per calendar year allowed by 40 CFR 63.6640(f)(2).
  - A. Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by Federal, State or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Illinois EPA or USEPA for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.
  - B. Emergency stationary RICE may be operated for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies, or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.
  - C. Emergency stationary RICE may be operated for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.
- iii. Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted towards the 100 hours per calendar year provided in 40 CFR 63.6640(f)(2). Except as provided in 40 CFR 63.6640(f)(4)(i) and (ii), the 50 hours per year for non-

emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

- A. The engine is dispatched by the local balancing authority or local transmission and distribution system operator.
  - B. The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
  - C. The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.
  - D. The power is power provided only to the facility itself or to support the local transmission and distribution system.
  - E. The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.
- j. Pursuant to 40 CFR 63.6665, Table 8 to 40 CFR 63 Subpart ZZZZ (see Attachment B) shows which parts of the General Provisions in 40 CFR 63.1 through 63.15 apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with any of the requirements of the General Provisions specified in Table 8: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing stationary RICE that combusts landfill or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, an existing emergency stationary RICE, or an existing limited use stationary RICE. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in the General Provisions specified in Table 8 except for the initial

notification requirements: A new stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new emergency stationary RICE, or a new limited use stationary RICE.

- k. Pursuant to 40 CFR 63.6675, emergency stationary RICE means any stationary reciprocating internal combustion engine that meets all of the criteria in paragraphs (1) through (3) of this definition. All emergency stationary RICE must comply with the requirements specified in 40 CFR 63.6640(f) in order to be considered emergency stationary RICE. If the engine does not comply with the requirements specified in 40 CFR 63.6640(f), then it is not considered to be an emergency stationary RICE under 40 CFR 63 Subpart ZZZZ:
  - i. The stationary RICE is operated to provide electrical power or mechanical work during an emergency situation. Examples include stationary RICE used to produce power for critical networks or equipment (including power supplied to portions of a facility) when electric power from the local utility (or the normal power source, if the facility runs on its own power production) is interrupted, or stationary RICE used to pump water in the case of fire or flood, etc.
  - ii. The stationary RICE is operated under limited circumstances for situations not included in paragraph (1) of this definition, as specified in 40 CFR 63.6640(f).
  - iii. The stationary RICE operates as part of a financial arrangement with another entity in situations not included in paragraph (1) of this definition only as allowed in 40 CFR 63.6640(f)(2)(ii) or (iii) and 40 CFR 63.6640(f)(4)(i) or (ii).
- 11a. Pursuant to 40 CFR 80.510(b), beginning June 1, 2010. Except as otherwise specifically provided in 40 CFR 80 Subpart I, all NR and LM diesel fuel is subject to the following per-gallon standards:
  - i. Sulfur content 15ppm maximum for NR diesel fuel.
  - ii. Cetane index or aromatic content, as follows:
    - A. A minimum cetane index of 40; or
    - B. A maximum aromatic content of 35 volume percent.
- 12a. In the event that the operation of this source results in an odor nuisance, the Permittee shall take appropriate and necessary actions to minimize odors, including but not limited to, changes in raw material or installation of controls, in order to eliminate the odor nuisance.
- b. The diesel-powered emergency generator sets shall only be operated with distillate fuel oil grades No. 1 and 2 (i.e., diesel) as the fuel. The use of any other fuel in any of the emergency generator sets requires

that the Permittee first obtain a construction permit from the Illinois EPA and then perform stack testing to verify compliance with all applicable requirements.

- c. Organic liquid by-products or waste materials shall not be used in any emission unit at this source set without written approval from the Illinois EPA.
  - d. The Illinois EPA shall be allowed to sample all fuels stored at the above location.
- 13a. Emissions from and operation of four (4) 1,500 kW (2,250 engine HP) diesel-powered emergency engine/generators shall not exceed the following limits:
- i. Hours of Operation: 200 hours/year (each), 800 hours/year (total)
  - ii. Emissions from the combustion of fuel oil:

<u>Pollutant</u>	<u>Emission Factor</u> (lb/HP-hr)	<u>Emissions</u>	
		lbs/Hr (each Genset)	Tons/Year (4 Gensets)
Carbon Monoxide (CO)	0.0055	12.38	4.95
Nitrogen Oxides (NO <sub>x</sub> )	0.024	54.00	21.60
Particulate Matter (PM)	0.0007	1.58	0.63
Sulfur Dioxide (SO <sub>2</sub> )	0.00227	5.10	2.04
Volatile Organic Material (VOM)	0.00064	1.44	0.58

These limits are based on the maximum engine output (2,250 hp, each), the maximum hours of operation, sulfur content of 0.28% by weight, and standard emission factors (Tables 3.4-1, AP-42, Fifth Edition, Volume I, Supplement B, October 1996).

- b. Emissions from and operation of three (3) 1,750 kW (2,606 engine HP) diesel-powered emergency engine/generators shall not exceed the following limits:
- i. Hours of Operation: 200 hours/year (each), 600 hours/year (total)
- ii. Emissions from the combustion of fuel oil:

<u>Pollutant</u>	<u>Emission Factor</u> (lb/HP-hr)	<u>Emissions</u>	
		lbs/Hr (each Genset)	Tons/Year (3 Gensets)
Carbon Monoxide (CO)	0.0055	14.33	4.30
Nitrogen Oxides (NO <sub>x</sub> )	0.024	62.54	18.76
Particulate Matter (PM)	0.0007	1.82	0.55
Sulfur Dioxide (SO <sub>2</sub> )	0.00227	5.90	1.77
Volatile Organic Material (VOM)	0.00064	1.67	0.50

These limits are based on the maximum engine output (2,606 hp, each), the maximum hours of operation, sulfur content of 0.28% by weight, and standard emission factors (Tables 3.4-1, AP-42, Fifth Edition, Volume I, Supplement B, October 1996).

- c. Emissions and operation of the two (2) 2,500 kW diesel-powered backup generator sets will not exceed the following:

i. Hours of Operation: 500 hours/year (each), 1,000 hours/year (total)

ii. Emissions from the combustion of fuel oil:

<u>Pollutant</u>	<u>Emission Factor</u> (lb/kW-hr)	<u>Emissions</u>	
		lbs/Hr (each Genset)	Tons/Year (2 Gensets)
Carbon Monoxide (CO)	0.00772	19.29	9.65
Nitrogen Oxides (NO <sub>x</sub> )	0.01411	35.27	17.64
Particulate Matter (PM)	0.00044	1.10	0.55
Sulfur Dioxide (SO <sub>2</sub> )	0.00002	0.04	0.02
Volatile Organic Material (VOM)	0.00287	7.17	3.58

These limits are based on emission factors derived from 40 CFR 89.112(a) for units with rated power rating greater than 560 kW, except for sulfur dioxide which is based on the standard factor (Table 3.4-1, AP-42, Fifth Edition, Volume I, Supplement B, October 1996) with a fuel sulfur content (0.0015%). Emission totals shall be calculated by multiplying the diesel generator set runtime and the emission factors for each pollutant.

- d. Compliance with the annual limits of this permit shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total).
14. This permit is issued based on the Potential to Emit (PTE) for Hazardous Air Pollutants (HAPs) as listed in Section 112(b) of the Clean Air Act from this source being less than 10 tons/year of any single HAP and 25 tons/year of any combination of such HAPs. As a result, this permit is issued based on the emissions of all HAPs from this source not triggering the requirements to obtain a CAAPP permit from the Illinois EPA.
15. This permit is issued based on the diesel-powered emergency generator sets DG1 and DG2 each having a displacement of less than 30 liters per cylinder and have been certified by the manufacturer to meet the standards of 40 CFR 60.4202(a) through (d). As a result this permit is issued based on the 2,250 kW diesel-powered emergency generator sets (DG1 and DG2) not being subject to the testing requirements of 40 CFR 60.8.

16. Pursuant to 40 CFR 60.4209(a), if you are an owner or operator, you must meet the monitoring requirements of 40 CFR 60.4209. In addition, you must also meet the monitoring requirements specified in 40 CFR 60.4211. If you are an owner or operator of an emergency stationary CI internal combustion engine, you must install a non-resettable hour meter prior to startup of the engine.
- 17a. Pursuant to 40 CFR 60.7(b), any owner or operator subject to the provisions of 40 CFR Part 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.
- b. Pursuant to 40 CFR 60.7(f), any owner or operator subject to the provisions of 40 CFR Part 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by 40 CFR Part 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports, and records.
18. Pursuant to 40 CFR 60.4214(b), if the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to 40 CFR 60 Subpart IIII, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.
19. Pursuant to 40 CFR 63.6625(f), if you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.
- 20a. Pursuant to 40 CFR 63.6625(f), if you own or operate an existing emergency stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions or an existing emergency stationary RICE located at an area source of HAP emissions, you must install a non-resettable hour meter if one is not already installed.
- b. Pursuant to 40 CFR 63.6625(j), if you own or operate a stationary SI engine that is subject to the work, operation or management practices

in items 6, 7, or 8 of Table 2c to 40 CFR 63 Subpart ZZZZ or in items 5, 6, 7, 9, or 11 of Table 2d to 40 CFR 63 Subpart ZZZZ, you have the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d to 40 CFR 63 Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to 40 CFR 63 Subpart ZZZZ. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine.

21. Pursuant to 40 CFR 63.10(b)(3), if an owner or operator determines that his or her stationary source that emits (or has the potential to emit, without considering controls) one or more hazardous air pollutants regulated by any standard established pursuant to Section 112(d) or (f) of the Clean Air Act, and that stationary source is in the source category regulated by the relevant standard, but that source is not subject to the relevant standard (or other requirement established under 40 CFR Part 63) because of limitations on the source's potential to emit or an exclusion, the owner or operator must keep a record of the applicability determination on site at the source for a period of 5 years after the determination, or until the source changes its operations to become an unaffected source, whichever comes first. The record of the applicability determination must be signed by the person making the determination and include an analysis (or other information) that demonstrates why the owner or operator believes the source is unaffected (e.g., because the source is an area source). The analysis (or other information) must be sufficiently detailed to allow the USEPA and/or Illinois EPA to make a finding about the source's applicability status with regard to the relevant standard or other requirement. If relevant, the analysis must be performed in accordance with requirements established in relevant subparts of 40 CFR Part 63 for this purpose for particular categories of stationary sources. If relevant, the analysis should be performed in accordance with USEPA guidance materials published to assist sources in making applicability determinations under Section 112 of the Clean Air Act, if any. The requirements to determine applicability of a standard under 40 CFR 63.1(b)(3) and to record the results of that determination under 40 CFR



63.10(b)(3) shall not by themselves create an obligation for the owner or operator to obtain a Title V permit.

- 22a. Pursuant to 40 CFR 63.6655(a), if you must comply with the emission and operating limitations, you must keep the records described in 40 CFR 63.6655(a)(1) through (a)(5), (b)(1) through (b)(3) and (c).
- i. A copy of each notification and report that you submitted to comply with 40 CFR 63 Subpart ZZZZ, including all documentation supporting any Initial Notification or Notification of Compliance Status that you submitted, according to the requirement in 40 CFR 63.10(b)(2)(xiv).
  - ii. Records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment.
  - iii. Records of performance tests and performance evaluations as required in 40 CFR 63.10(b)(2)(viii).
  - iv. Records of all required maintenance performed on the air pollution control and monitoring equipment.
  - v. Records of actions taken during periods of malfunction to minimize emissions in accordance with 40 CFR 63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.
- b. Pursuant to 40 CFR 63.6655(d), you must keep the records required in Table 6 of 40 CFR 63 Subpart ZZZZ to show continuous compliance with each emission or operating limitation that applies to you.
- c. Pursuant to 40 CFR 63.6655(e), you must keep records of the maintenance conducted on the stationary RICE in order to demonstrate that you operated and maintained the stationary RICE and after-treatment control device (if any) according to your own maintenance plan if you own or operate any of the following stationary RICE.
- i. An existing stationary emergency RICE.
  - ii. An existing stationary CI RICE located at an area source of HAP emissions subject to management practices as shown in Table 2d to 40 CFR 63 Subpart ZZZZ.
- d. Pursuant to 40 CFR 63.6655(f)(2), if you own or operate an existing emergency stationary RICE located at an area source of HAP emissions that does not meet the standards applicable to non-emergency engines, you must keep records of the hours of operation of the engine that is recorded through the non-resettable hour meter. The owner or operator must document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours

- are spent for non-emergency operation. If the engines are used for the purposes specified in 40 CFR 63.6640(f)(2)(ii) or (iii) or 40 CFR 63.6640(f)(4)(ii), the owner or operator must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation for these purposes.
- e. Pursuant to 40 CFR 63.6660(a), your records must be in a form suitable and readily available for expeditious review according to 40 CFR 63.10(b)(1).
  - f. Pursuant to 40 CFR 63.6660(b), as specified in 40 CFR 63.10(b)(1), you must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record.
  - g. Pursuant to 40 CFR 63.6660(c), you must keep each record readily accessible in hard copy or electronic form for at least 5 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 40 CFR 63.10(b)(1).
- 23a. The Permittee shall maintain records of the following items so as to demonstrate compliance with the conditions of this permit:
- i. Date and duration of startup of the engines, (i.e., start time and time normal operation achieved, and stable operation at load);
  - ii. The sulfur content of the distillate fuel oil used at the source (% weight), this shall be recorded for each shipment of fuel oil delivered to the source;
  - iii. Diesel-powered generator sets runtime (hours/month, hours/year); and
  - iv. Monthly and annual emissions of CO, NO<sub>x</sub>, PM, SO<sub>2</sub>, and VOM from the source with supporting calculations (tons/month and tons/year).
- b. All records and logs required by Condition 23(a) of this permit shall be retained at a readily accessible location at the source for at least five (5) years from the date of entry and shall be made available for inspection and copying by the Illinois EPA or USEPA upon request. Any records retained in an electronic format (e.g., computer storage device) shall be capable of being retrieved and printed on paper during normal source office hours so as to be able to respond to an Illinois EPA or USEPA request for records during the course of a source inspection.
- 24a. Pursuant to 40 CFR 63.6640(b), you must report each instance in which you did not meet each emission limitation or operating limitation in Tables 1a and 1b, Tables 2a and 2b, Table 2c, and Table 2d to 40 CFR 63 Subpart ZZZZ that apply to you. These instances are deviations from the emission and operating limitations in 40 CFR 63 Subpart ZZZZ.

These deviations must be reported according to the requirements in 40 CFR 63.6650. If you change your catalyst, you must reestablish the values of the operating parameters measured during the initial performance test. When you reestablish the values of your operating parameters, you must also conduct a performance test to demonstrate that you are meeting the required emission limitation applicable to your stationary RICE.

- b. Pursuant to 40 CFR 63.6640(e), you must also report each instance in which you did not meet the requirements in Table 8 to 40 CFR 63 Subpart ZZZZ that apply to you. If you own or operate a new or reconstructed stationary RICE with a site rating of less than or equal to 500 brake HP located at a major source of HAP emissions (except new or reconstructed 4SLB engines greater than or equal to 250 and less than or equal to 500 brake HP), a new or reconstructed stationary RICE located at an area source of HAP emissions, or any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to 40 CFR 63 Subpart ZZZZ: An existing 2SLB stationary RICE, an existing 4SLB stationary RICE, an existing emergency stationary RICE, an existing limited use stationary RICE, or an existing stationary RICE which fires landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis. If you own or operate any of the following RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, you do not need to comply with the requirements in Table 8 to 40 CFR 63 Subpart ZZZZ, except for the initial notification requirements: a new or reconstructed stationary RICE that combusts landfill gas or digester gas equivalent to 10 percent or more of the gross heat input on an annual basis, a new or reconstructed emergency stationary RICE, or a new or reconstructed limited use stationary RICE.
- c. Pursuant to 40 CFR 63.6645(a), you must submit all of the notifications in 40 CFR 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) that apply to you by the dates specified if you own or operate any of the following;
  - i. An existing stationary CI RICE located at an area source of HAP emissions.
  - ii. This requirement does not apply if you own or operate an existing stationary RICE less than 100 HP, an existing stationary emergency RICE, or an existing stationary RICE that is not subject to any numerical emission standards.
- d. Pursuant to 40 CFR 63.6650(a), you must submit each report in Table 7 of 40 CFR 63 Subpart ZZZZ that applies to you.

Table 7 to Subpart ZZZZ of Part 63—Requirements for Reports

As stated in 40 CFR 63.6650, you must comply with the following requirements for reports:

For each . . .	You must submit a . . .	The report must contain . . .	You must submit the report . . .
4. Emergency stationary RICE that operate or are contractually obligated to be available for more than 15 hours per year for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii) or that operate for the purposes specified in 40 CFR 63.6640(f)(4)(ii)	Report	a. The information in 40 CFR 63.6650(h)(1)	i. annually according to the requirements in 40 CFR 63.6650(h)(2)-(3).

- e. Pursuant to 40 CFR 63.6650(c), the Compliance report must contain the information in 40 CFR 63.6650(c)(1) through (6).
  - i. Company name and address.
  - ii. Statement by a responsible official, with that official's name, title, and signature, certifying the accuracy of the content of the report.
  - iii. Date of report and beginning and ending dates of the reporting period.
  - iv. If you had a malfunction during the reporting period, the compliance report must include the number, duration, and a brief description for each type of malfunction which occurred during the reporting period and which caused or may have caused any applicable emission limitation to be exceeded. The report must also include a description of actions taken by an owner or operator during a malfunction of an affected source to minimize emissions in accordance with 40 CFR 63.6605(b), including actions taken to correct a malfunction.
  - v. If there are no deviations from any emission or operating limitations that apply to you, a statement that there were no deviations from the emission or operating limitations during the reporting period
- f. Pursuant to 40 CFR 63.6650(d), for each deviation from an emission or operating limitation that occurs for a stationary RICE where you are not using a CMS to comply with the emission or operating limitations in 40 CFR 63 Subpart ZZZZ, the Compliance report must contain the information in 40 CFR 63.6650(c)(1) through (4) and the information in 40 CFR 63.6650(d)(1) and (2).
  - i. The total operating time of the stationary RICE at which the deviation occurred during the reporting period.
  - ii. Information on the number, duration, and cause of deviations (including unknown cause, if applicable), as applicable, and the corrective action taken.

- g. Pursuant to 40 CFR 63.6650(h), if you own or operate an emergency stationary RICE with a site rating of more than 100 brake HP that operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in 40 CFR 63.6640(f)(4)(ii), you must submit an annual report according to the requirements in 40 CFR 63.6650(h)(1) through (3).
- i. The report must contain the following information:
  - A. Company name and address where the engine is located.
  - B. Date of the report and beginning and ending dates of the reporting period.
  - C. Engine site rating and model year.
  - D. Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.
  - E. Hours operated for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii), including the date, start time, and end time for engine operation for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii).
  - F. Number of hours the engine is contractually obligated to be available for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii).
  - G. Hours spent for operation for the purpose specified in 40 CFR 63.6640(f)(4)(ii), including the date, start time, and end time for engine operation for the purposes specified in 40 CFR 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.
  - H. If there were no deviations from the fuel requirements in 40 CFR 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.
  - I. If there were deviations from the fuel requirements in 40 CFR 63.6604 that apply to the engine (if any), information on the number, duration, and cause of deviations, and the corrective action taken.
- ii. The first annual report must cover the calendar year 2015 and must be submitted no later than March 31, 2016. Subsequent annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

- iii. The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through EPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form specific to 40 CFR 63 Subpart ZZZZ is not available in CEDRI at the time that the report is due, the written report must be submitted to the Illinois EPA or USEPA at the appropriate address listed in 40 CFR 63.13.
- 25a. If there is an exceedance of or a deviation from the requirements of this permit as determined by the records required by this permit or otherwise, the Permittee shall submit a report to the Illinois EPA's Bureau of Air Compliance Section in Springfield, Illinois within thirty (30) days after the exceedance or deviation. The report shall identify the duration and the emissions impact of the exceedance or deviation, a copy of the relevant records and information to resolve the exceedance or deviation, and a description of the efforts to reduce emissions from, and the duration of exceedance or deviation, and to prevent future occurrences of any such exceedance or deviation.
- b. One (1) copy of required reports and notifications shall be sent to:

Illinois Environmental Protection Agency  
Division of Air Pollution Control  
Compliance Section (#40)  
P.O. Box 19276  
Springfield, Illinois 62794-9276

If you have any questions concerning this permit, please call Jocelyn Stakely at 217/785-1705.

Raymond E. Pilapil  
Acting Manager, Permit Section  
Division of Air Pollution Control

Date Signed: \_\_\_\_\_

REP:JRS:jws

cc: Illinois EPA, Region 1  
Lotus Notes

Attachment A - Emissions Summary

This attachment provides a summary of the maximum emission from the emergency generator sets, operating in compliance with the requirements of this federally enforceable permit. In preparing this summary, the Agency used the annual operating scenario, which results in maximum emissions from such a plant. The resulting maximum emissions are below the levels, (e.g., 100 tons/year for NO<sub>x</sub>) at which this source would be considered a major source for purposes of the Clean Air Act Permit Program. Actual emissions from this source will be less than predicted in this summary to the extent that less fuel is used, and control measures are more effective than required in this permit.

<u>Emission Unit</u>	E M I S S I O N S (Tons/Year)				
	<u>CO</u>	<u>NO<sub>x</sub></u>	<u>PM</u>	<u>SO<sub>2</sub></u>	<u>VOM</u>
Four (4) 1,500 kW (2,250 engine HP) emergency generator sets	4.95	21.60	0.63	2.04	0.58
Three (3) 1,750 kW (2,606 engine HP) emergency generator sets	4.30	18.76	0.55	1.77	0.50
Diesel-Powered Emergency Generator Sets DG1 and DG2	<u>9.65</u>	<u>17.64</u>	<u>0.55</u>	<u>0.02</u>	<u>3.58</u>
Totals	18.90	58.00	1.73	3.83	4.66

Attachment B -- Table 8 to Subpart ZZZZ of Part 63--Applicability of General Provisions to Subpart ZZZZ.

As stated in 40 CFR 63.6665, you must comply with the following applicable general provisions.

General provisions citation	Subject of citation	Applies to subpart	Explanation
\$63.1	General applicability of the General Provisions	Yes.	
\$63.2	Definitions	Yes	Additional terms defined in 40 CFR 63.6675.
\$63.3	Units and abbreviations	Yes.	
\$63.4	Prohibited activities and circumvention	Yes.	
\$63.5	Construction and reconstruction	Yes.	
\$63.6(a)	Applicability	Yes.	
\$63.6(b)(1)-(4)	Compliance dates for new and reconstructed sources	Yes.	
\$63.6(b)(5)	Notification	Yes.	
\$63.6(b)(6)	[Reserved]		
\$63.6(b)(7)	Compliance dates for new and reconstructed area sources that become major sources	Yes.	
\$63.6(c)(1)-(2)	Compliance dates for existing sources	Yes.	
\$63.6(c)(3)-(4)	[Reserved]		
\$63.6(c)(5)	Compliance dates for existing area sources that become major sources	Yes.	
\$63.6(d)	[Reserved]		
\$63.6(e)	Operation and maintenance	No.	
\$63.6(f)(1)	Applicability of standards	No.	
\$63.6(f)(2)	Methods for determining compliance	Yes.	
\$63.6(f)(3)	Finding of compliance	Yes.	
\$63.6(g)(1)-(3)	Use of alternate standard	Yes.	
\$63.6(h)	Opacity and visible emission standards	No	Subpart ZZZZ does not contain opacity or visible emission standards.
\$63.6(i)	Compliance extension procedures and criteria	Yes.	
\$63.6(j)	Presidential compliance exemption	Yes.	
\$63.7(a)(1)-(2)	Performance test dates	Yes	Subpart ZZZZ contains performance test dates at 40 CFR 63.6610, 63.6611, and 63.6612.
\$63.7(a)(3)	CAA section 114 authority	Yes.	
\$63.7(b)(1)	Notification of performance test	Yes	Except that 40 CFR 63.7(b)(1) only applies as specified in 40 CFR 63.6645.
\$63.7(b)(2)	Notification of rescheduling	Yes	Except that 40 CFR



			63.7(b)(2) only applies as specified in 40 CFR 63.6645.
\$63.7(c)	Quality assurance/test plan	Yes	Except that 40 CFR 63.7(c) only applies as specified in 40 CFR 63.6645.
\$63.7(d)	Testing facilities	Yes.	
\$63.7(e)(1)	Conditions for conducting performance tests	No.	Subpart ZZZZ specifies conditions for conducting performance tests at 40 CFR 63.6620.
\$63.7(e)(2)	Conduct of performance tests and reduction of data	Yes	Subpart ZZZZ specifies test methods at 40 CFR 63.6620.
\$63.7(e)(3)	Test run duration	Yes.	
\$63.7(e)(4)	Administrator may require other testing under section 114 of the CAA	Yes.	
\$63.7(f)	Alternative test method provisions	Yes.	
\$63.7(g)	Performance test data analysis, recordkeeping, and reporting	Yes.	
\$63.7(h)	Waiver of tests	Yes.	
\$63.8(a)(1)	Applicability of monitoring requirements	Yes	Subpart ZZZZ contains specific requirements for monitoring at 40 CFR 63.6625.
\$63.8(a)(2)	Performance specifications	Yes.	
\$63.8(a)(3)	[Reserved]		
\$63.8(a)(4)	Monitoring for control devices	No.	
\$63.8(b)(1)	Monitoring	Yes.	
\$63.8(b)(2)-(3)	Multiple effluents and multiple monitoring systems	Yes.	
\$63.8(c)(1)	Monitoring system operation and maintenance	Yes.	
\$63.8(c)(1)(i)	Routine and predictable SSM	No	
\$63.8(c)(1)(ii)	SSM not in Startup Shutdown Malfunction Plan	Yes.	
\$63.8(c)(1)(iii)	Compliance with operation and maintenance requirements	No	
\$63.8(c)(2)-(3)	Monitoring system installation	Yes.	
\$63.8(c)(4)	Continuous monitoring system (CMS) requirements	Yes	Except that subpart ZZZZ does not require Continuous Opacity Monitoring System (COMS).
\$63.8(c)(5)	COMS minimum procedures	No	Subpart ZZZZ does not require COMS.
\$63.8(c)(6)-(8)	CMS requirements	Yes	Except that subpart ZZZZ does not require COMS.
\$63.8(d)	CMS quality control	Yes.	
\$63.8(e)	CMS performance evaluation	Yes	Except for 40 CFR 63.8(e)(5)(ii), which applies to COMS.
		Except that	

		40 CFR 63.8(e) only applies as specified in 40 CFR 63.6645.	
\$63.8(f)(1)-(5)	Alternative monitoring method	Yes	Except that 40 CFR 63.8(f)(4) only applies as specified in 40 CFR 63.6645.
\$63.8(f)(6)	Alternative to relative accuracy test	Yes	Except that 40 CFR 63.8(f)(6) only applies as specified in 40 CFR 63.6645.
\$63.8(g)	Data reduction	Yes	Except that provisions for COMS are not applicable. Averaging periods for demonstrating compliance are specified at 40 CFR 63.6635 and 63.6640.
\$63.9(a)	Applicability and State delegation of notification requirements	Yes.	
\$63.9(b)(1)-(5)	Initial notifications	Yes Except that 40 CFR 63.9(b) only applies as specified in 40 CFR 63.6645.	Except that 40 CFR 63.9(b)(3) is reserved.
\$63.9(c)	Request for compliance extension	Yes	Except that 40 CFR 63.9(c) only applies as specified in 40 CFR 63.6645.
\$63.9(d)	Notification of special compliance requirements for new sources	Yes	Except that 40 CFR 63.9(d) only applies as specified in 40 CFR 63.6645.
\$63.9(e)	Notification of performance test	Yes	Except that 40 CFR 63.9(e) only applies as specified in 40 CFR 63.6645.
\$63.9(f)	Notification of visible emission (VE)/opacity test	No	Subpart ZZZZ does not contain opacity or VE standards.
\$63.9(g)(1)	Notification of performance evaluation	Yes	Except that 40 CFR 63.9(g) only applies as specified in 40 CFR 63.6645.
\$63.9(g)(2)	Notification of use of COMS data	No	Subpart ZZZZ does not contain opacity or VE standards.

\$63.9(g)(3)	Notification that criterion for alternative to RATA is exceeded	Yes Except that 40 CFR 63.9(g) only applies as specified in 40 CFR 63.6645.	If alternative is in use.
\$63.9(h)(1)-(6)	Notification of compliance status	Yes	Except that notifications for sources using a CEMS are due 30 days after completion of performance evaluations. 40 CFR 63.9(h)(4) is reserved. Except that 40 CFR 63.9(h) only applies as specified in 40 CFR 63.6645.
\$63.9(i)	Adjustment of submittal deadlines	Yes.	
\$63.9(j)	Change in previous information	Yes.	
\$63.10(a)	Administrative provisions for recordkeeping/reporting	Yes.	
\$63.10(b)(1)	Record retention	Yes.	Except that the most recent 2 years of data do not have to be retained on site.
\$63.10(b)(2)(i)-(v)	Records related to SSM	No.	
\$63.10(b)(2)(vi)-(xi)	Records	Yes.	
\$63.10(b)(2)(xii)	Record when under waiver	Yes.	
\$63.10(b)(2)(xiii)	Records when using alternative to RATA	Yes	For CO standard if using RATA alternative.
\$63.10(b)(2)(xiv)	Records of supporting documentation	Yes.	
\$63.10(b)(3)	Records of applicability determination	Yes.	
\$63.10(c)	Additional records for sources using CEMS	Yes	Except that 40 CFR 63.10(c)(2)-(4) and (9) are reserved.
\$63.10(d)(1)	General reporting requirements	Yes.	
\$63.10(d)(2)	Report of performance test results	Yes.	
\$63.10(d)(3)	Reporting opacity or VE observations	No	Subpart ZZZZ does not contain opacity or VE standards.
\$63.10(d)(4)	Progress reports	Yes.	
\$63.10(d)(5)	Startup, shutdown, and malfunction reports	No.	

\$63.10(e)(1) and (2)(i)	Additional CMS Reports	Yes.	
\$63.10(e)(2)(ii)	COMS-related report	No	Subpart ZZZZ does not require COMS.
\$63.10(e)(3)	Excess emission and parameter exceedances reports	Yes.	Except that 40 CFR 63.10(e)(3)(i)(C) is reserved.
\$63.10(e)(4)	Reporting COMS data	No	Subpart ZZZZ does not require COMS.
\$63.10(f)	Waiver for recordkeeping/reporting	Yes.	
\$63.11	Flares	No.	
\$63.12	State authority and delegations	Yes.	
\$63.13	Addresses	Yes.	
\$63.14	Incorporation by reference	Yes.	
\$63.15	Availability of information	Yes.	